ADDENDA

ADDENDUM NUMBER 1

DATE: April 15, 2016

PROJECT: Ashland Receiving and Storage Building

BGS PROJECT 2652

NUMBER:

OWNER: State of Maine Bureau of Parks and Lands

ENGINEER: Mid-South Engineering Co.

TO: All Plan Holders

This Addendum forms a part of the Contract Documents and modifies the Bidding Documents dated April 4, 2016 with amendments and additions noted below.

Acknowledge receipt of this addendum in the space provided in the Bid Form. Failure to do so may disqualify the Bidder.

This Addendum consists of two (2) pages and is in the form of additions/clarifications by the Engineer.

Ques. 1 Confirm roof sheathing thickness.

Ans. Roof sheathing is to be Advantech, as manufactured by Huber Engineered Woods and is to be one half inch (1/2") in thickness.

Ques. 2 Confirm concrete wall thickness.

Ans. Concrete wall thickness is 10 inches. Concrete strength is 3000 psi at 28 days.

Ques. 3 Are the angles at the overhead doors painted or just carbon steel.

<u>Ans.</u> The angles are to be carbon steel, no paint but free of rust and at minimum, power tool cleaned per SSPC- SP3.

Ques. 4 What is the gauge of the fascia metal? Is it the intent to use coil from the metal siding supplier?

<u>Ans.</u> It is not required to utilize coil from the metal siding supplier. Colors will be chosen by the representatives of the Bureau of Parks and Lands when a contractor for the project has been selected. Utilize Napco Aluminum Trim Coil in standard thickness (or equal).

Ques. 5 Is there a floor drain in the slab.

Ans. There is no floor drain in the slab.

Ques. 6 The question was asked as to what the title of the "OBLIGEE" is on several of the bond

forms and what the proper mailing address of the "OBLIGEE" is.

Ans. The title should be: The Treasurer of the State of Maine

The Obligee's address is: 39 State House Station, Augusta, Maine 04333-0039

Note: Several documents require the bidder to complete using Microsoft Word, specifically the

following:

00 41 13 Contractor Bid Form 00 43 13 Contractor Bid Bond

These documents are available on the State website in Microsoft Word format with all other documents for this project at the BGS website: http://www.maine.gov/bgs/constrpublic/contractors/gc_rfp.htm.

END OF DOCUMENT